

Certificate of Conformity

This is to Certify

Purepine Mouldings SmartClad™ Weatherboard System

Product Description

SmartClad™ Weatherboards 18 x 140mm, 18 x 185mm
SmartClad™ Starter Boards 30 x 140mm, 30 x 185mm
SmartClip™ - 40 x 10mm ABS fixing clip
SmartClad™ Screws – stainless steel or galvanized 65mm x 8 gauge
SmartClad™ Pre-scribed Scriber 40 x 10mm, Pre-scribed Facing 66mm x 34mm, Box Corner 100/88 x 34mm, Eaves Moulding 40 x 27mm, Sill 55 x 42mm, Internal Corner Scriber 36 x 36mm, Joint & Corner Soakers 150/200 x 49mm

Complies with the Building Code of New Zealand:

When used in accordance with the conditions and limitations of this certificate, Purepine Mouldings Ltd SmartClad weatherboard system will comply with the following NZBC clauses;

- B1 Structure – B1.3.1, B1.3.2, B1.3.3 (a, c, f, h, j, q) B1.3.4 (a-e)
- B2 Durability – B2.3.1 (b & c), B2.3.2 (a)
- E2 External Moisture – E2.3.2, E2.3.5
- F2 Hazardous Building Materials – F2.3.1

Subject to the following conditions and limitations:

1. SmartClad™ Weatherboard System must be installed by a Licensed Building Practitioner to the specifications listed in SmartClad™ Technical Manual version 10.14.
2. SmartClad™ must be painted a light colour (greater than 45LRV) and maintained in accordance with SmartClad™ Technical Manual version 10.14.
3. The technical manual is not exhaustive in its scope. Responsibility for design lies with the specifier or responsible party for the project to ensure the final design meets the requirements of the intended application and the NZBC.
4. For designs outside the scope of the technical manual, specific design must be undertaken by the architect or designer.
5. Purepine Mouldings Ltd. will notify AsureQuality Ltd in accordance with Regulation 15 of the Building (Product Certification) Regulations 2008



John McKay, Chief Executive Officer, AsureQuality Limited

Date of Issue 20th September 2016

Certificate Number AQ200916CMNZ



Product Use and Scope

SmartClad™ Weatherboard System

The SmartClad™ Bevelback Cavity and Direct Fixed Weatherboards are external wall claddings for use on residential and light commercial buildings. To be used in buildings within the scope of NZS3604:2011 and E2/AS1 (section 9.4) with the exception of fixing.

Certificate Holder

Purepine Mouldings Limited
554 Jellicoe Street
Te Puke
Ph: 0800 768 253
Email: info@smartclad.co.nz
Web: www.smartclad.co.nz



JAS-ANZ



www.jas-anz.org/register

CodeMark Certification Body

AsureQuality, 11 Hull Road
Mt Maunganui, New Zealand
T. 0508 00 11 22
www.asurequality.com